



“STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance”

B(8)



DELHI JAL BOARD ;(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT HAIDERPUR,
DELHI-110085



**THE TEST REPORT IS
FOR THIS PARTICULAR
WATER SAMPLE ONLY**

(ISO Certified 9001:2015)

Water sample collected from DJB stored Water in the premises of Orleans The School, F-19 Sector-09 Rohini Delhi-110085 vide challan No. 339 Dated 23.03.2023.

S. No.	PARAMETERS	UNITS	Limit as per B.I.S.10500:2012		S1
			Acceptable	Permissible	
1.	Date of collection	--	---	---	12.04.2023
2.	Date of Analysis	--	---	---	14.04.2023
3.	Colour	C.U.	5	15	<1 C.U.
4.	Odour	--	Agreeable		Agreeable
5.	Turbidity	N.T.U	1.0	5.0	1.92
6.	p ^H value	--	6.5 to 8.5	N.R.	7.3
7.	Electrical Conductivity	µmhos/cm	----	----	279.0
8.	Total Dissolved Solid	(mg/l)	500	2000	181.35
CHEMICAL EXAMINATION					
9.	Phenolphthalein Alkalinity	(mg/l)	----	----	Nil
10.	Total Alkalinity	(mg/l)	200	600	79.0
11.	Total Hardness	(mg/l)	200	600	118.0
12.	Calcium Hardness	(mg/l)	200	600	81.0
13.	Magnesium Hardness	(mg/l)	200	600	37.0
14.	Calcium as Ca	(mg/l)	75	200	32.4
15.	Magnesium as mg	(mg/l)	30	100	8.38
16.	Ammonia (as NH ₃ -N)	(mg/l)	0.5	N.R.	*ND
17.	Nitrite -Nitrogen (N)	(mg/l)	---	---	*ND
18.	Nitrate (NO ₃)	(mg/l)	45	N.R.	2.70
19.	Sulphate (SO ₄)	(mg/l)	200	400	43.0
20.	Chloride (Cl)	(mg/l)	250	1000	14.0
21.	Iron (Fe)	(mg/l)	1.0	N.R.	0.08
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.32
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	*N.D.
24.	Residual Chlorine	(mg/l)	0.2	1.0	0.75
BACTERIOLOGICAL EXAMINATION					
25.	Coli form per 100 ml at 37°C	MPN/100 mL	0		0

*N.D. - Not Detectable

Remarks: On the basis of above tested parameters, water sample (S1) confirm to drinking water specification I.S.10500:2012 and may be used for drinking purpose.


Asstt. Chemist
14/4/23

Chemist/Bacteriologist
15/4/23

A.C.W.A. (HP- I)

C.W.A. (W&S)-II




Orleans — The School —
Above and Beyond..

F- 19, Sector-8, Rohini, Delhi-110085

Affiliated to Central Board of Secondary Education (CBSE)

Recog. By Directorate of Education, Govt. of NCT, Delhi

27948500, 27942400

Email: principal@orleanstheschool.in, Website: www.orleanstheschool.in

School ID - 1413281

Ref No: -OTS/2022-23/25

Date : 18.03.2023

Office of Deputy Health Officer
North Delhi Municipal Corporation
Public Health Department : Rohini Zone
Sector – 05, Rohini, Delhi-110085

o/c

Subject: - Renewal of School Health Certificate in respect of Orleans – The School, F-19, Sector-8, New Delhi-110085

Dear Sir/Madam,

This is to inform you that a School Health Certificate was issued vide your letter No. NO: DHO/RZ/2022/800 dated 14/03/2022 in respect of Orleans – The School formerly known as Tecnia International School, F-19, Sector-8, New Delhi-110085 is due for the renewal.

Orleans – The School is running under Babson (PSB) Educational Society, Kindly consider the attached documents accordingly and pursue the matter at the earliest.

You are requested to kindly extend the School Health Certificate and issue the same.

Your early action in this regard is highly obliged.


Regards

[Signature]
Principal



Enclosed:-

- 1) Copy of approval letter of DoE Reg. Change of name of the school i.e Tecnia International School to Orleans – The School
- 2) Copy of School Health Certificate dated 14.03.2022
- 3) Copy Fire Safety Certificate
- 4) Copy of Latest Electricity Bill
- 5) Copy of Payment Receipt of Water Bill (DJB)
- 6) Copy of Building Sanction Plan
- 7) Copy of Property Tax Challan



DIARY NO. *123*
DATE *18/03/23*
HEALTH DEPT
ROHINI ZONE

[Signature]



NORTH DELHI MUNICIPAL CORPORATION
(OFFICE OF DY. HEALTH OFFICER: ROHINI ZONE)
PUBLIC HEALTH DEPARTMENT SECTOR 5 ROHINI DELHI -110085
Email: dhorohinizone15@gmail.com Tel: 011-27052106

No.-DHO/RZ/2022/ 800


Dated:- 14/03/2022

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by Area Public health Inspector from Public Health department Rohini Zone inspected the M/s TECNIA INTERNATIONAL SCHOOL (SR.SEC. AFFILIATED TO CENTRAL BOARD OF SECONDARY EDUCATION (CBSE), Recog. By Directorate of Education, Govt. Of NCT, Delhi Situated at F-19 Sector-8, Rohini Delhi-110085 on 14.03.2022 and found that the TECNIA INTERNATIONAL SCHOOL has safe drinking water facilities for the students and members of staff of the institution and is maintaining the sanitation condition in the school building & the campus.

The above certificate is valid for the period of one year from date of issue.

PRINCIPAL
TECNIA INTERNATIONAL SCHOOL
(SR.SEC. AFFILIATED TO CENTRAL BOARD
OF SECONDARY EDUCATION (CBSE),
F-19 Sector-8, Rohini Delhi-110085


Dy. Health Office
Rohini Zone
Public Health Department
North Delhi Municipal Corporation
Rohini Zone

